

Legionella¹

Description

Species of the genus *Legionella* are Gram-negative, non-spore-forming, rod-shaped, aerobic bacteria. They contain branched-chain fatty acids, have a non-fermentative metabolism, and require L-cysteine and iron salts for growth. They have been placed in the family Legionellaceae, which contains the single genus *Legionella*; there are at least 42 species, which are listed in Table 5 (Drozanski, 1991; Adeleke et al., 1996; Hookey et al., 1996; Fry & Harrison, 1998; Riffard et al., 1998). The type species is *L. pneumophila*. Two other genera have been proposed but have not received general recognition (Garrity, Brown & Vickers, 1980): *Fluoribacter* for the blue-white fluorescing species such as *L. bozemanii* and *L. dumoffii*, and *Tatlockia* for the species *L. micdadei*. Some species of *Legionella* can be further differentiated into serotypes, of which there are at least 15 for *L. pneumophila* but so far no more than two for any other species.

Free-living legionellae are rod-shaped, 0.3–0.9µm wide and approximately 1.3µm long. They will grow to 2–6µm in vitro, but can form filaments 20µm or more in length. Although they are Gram-negative, legionellae actually stain poorly in the Gram procedure and by other similar staining methods, particularly in infected tissues. This has been attributed to the presence of the branched-chain fatty acids that are a major component of the cell walls. Other staining methods have been described, such as the silver impregnation method of Dieterle (Dieterle, 1927); the most effective methods include antibody-coupled fluorescent dyes and immunoperoxidase staining.

The legionellae are usually motile by means of one or more polar or subpolar flagellae. The cell wall consists of a cytoplasmic membrane on the inner surface, a thin peptidoglycan layer, and an outer membrane that contains the heat-stable lipopolysaccharides (LPS) with species- and serogroup-specific O antigens. There is no definitive evidence of a capsule.

The optimal temperature for in-vitro growth is 36°C (limits 15–43°C), with a generation time of 99 minutes under optimal conditions (Brenner, Fealey & Weaver, 1984; Brenner, 1986; Fallon, 1990; States et al., 1993). In the natural habitat—fresh water and soil—growth requires the presence of other bacteria or of protozoa, which are considered to be the natural hosts of legionellae (Rowbotham, 1980; Tison et al., 1980; Wadowsky & Lee, 1985; Fields et al., 1993).

Pathogenicity for humans

Legionellae were first detected in 1976 after a particularly notable outbreak of pneumonia in a hotel on the occasion of a United States army veterans' meeting (Fraser et al., 1977). Since that time, it has been established that these organisms are an important cause of pneumonia, both community-acquired (1–15%) (Lieberman et al., 1996; Butler & Breiman, 1998) and hospital-acquired (up to 50%) (Butler & Breiman, 1998). To date, disease due to *Legionella* has been detected almost exclusively in humans, but some animals (e.g. guinea-pigs, rats, mice, marmosets, and monkeys) are susceptible to experimental infection. One case of *Legionella* pneumonia has also been reported in a calf (Fabbi et al., 1998). Evidence of past infection can also be found in other animal species, including wild animals, but no animal reservoir of the bacteria or transmission between animals has been demonstrated (Collins, Cho & Reif, 1982; Boldur et al., 1987).

Two kinds of disease are observed in humans. Legionnaires disease is a severe pneumonia (incubation time 2–10 days); mortality is about 15% and *Legionella* may be detected in sputum and tissues. Pontiac fever is a febrile illness of 2–6 days' duration, with an incubation time of 1–7

(normally 3) days; it is non-pneumonic (cough is observed in about 50% of cases) and self-limiting, and accompanied by headache and myalgia. Bacteria are not detectable in body fluids or tissues nor are bacterial antigens found in urine, but blood antibodies are elevated (Glick et al., 1978; Fallon et al., 1993).

Legionnaires disease is commonly accompanied by extrapulmonary manifestations, such as renal failure, encephalopathy, and pericarditis (Oredugba et al., 1980; Posner et al., 1980; Riggs et al., 1982; Mayock, Skale & Kohler, 1983; Johnson, Raff & Van-Arsdall, 1984; Nelson et al., 1984). Lung abscesses, other local infections, and wound infections involving *L. pneumophila* and *L. dumoffi* have also been reported (Arnow, Boyko & Friedman, 1983; Bauling, Weil & Schroter, 1985; Lowry et al., 1991).

L. pneumophila serogroup 1 is most commonly isolated from patients (58% of isolates in England and Wales, 71.5% in the USA) (Joseph et al., 1994; Marston, Lipman & Breiman, 1994), followed by *L. pneumophila* serogroup 6 (Tang & Krishnan, 1993). Other serogroups of *L. pneumophila* and another 19 species of *Legionella* are associated to a varying degree with human disease. In the USA, *L. micdadei* is the second most frequent cause of Legionnaires disease and has also been repeatedly identified as the causative agent of Pontiac fever (Goldberg et al., 1989; Luttichau et al., 1998). In Australia, *L. longbeachae* seems to be an important cause of Legionnaires disease (Steele, Lanser & Sangster, 1990). Between 9.3% and 29.0% of infections are caused by species other than *L. pneumophila* (Tang & Krishnan, 1993; Joseph et al., 1994; Marston, Lipman & Breiman, 1994), but for most of these there are neither properly validated serological tests nor optimized isolation media (Edelstein, 1993).

Pathogenicity of *Legionella* in humans is largely dependent on host susceptibility. Children and young people are rarely affected, while immunocompromised individuals—especially transplant recipients—are at very high risk of disease. However, since any population may exhibit both extremes of susceptibility, even people considered to be “fit and well” may become ill (World Health Organization, 1990). Lieberman et al. (1996) observed that 39 out of 56 patients with community-acquired *Legionella* pneumonia had no chronic comorbidity, although coinfection with another microorganism was frequent. Smoking and alcoholism are commonly acknowledged to be predisposing factors, and infection is more common in males than females and in people over 40 years of age (World Health Organization, 1990; Butler & Breiman, 1998). Individual risk factors also include working more than 40 hours per week and spending nights away from home (Straus et al., 1996).

Individuals with terminal renal insufficiency or blood malignancies, people receiving steroid treatments, and severely immunocompromised individuals (including those with HIV/AIDS) are at significant risk for acquiring Legionnaires disease (Marston, Lipman & Breiman, 1994). Patients with chronic lung disease, cirrhosis of the liver, or diabetes are also at risk, though to a slightly lesser extent. An indwelling nasogastric tube is a further independent risk factor for nosocomial Legionnaires disease (Marrie et al., 1991; Blatt et al., 1993). Pontiac fever, by contrast, affects children and healthy adults just as frequently as immunocompromised individuals (Goldberg et al., 1989).

During an outbreak of disease, exposed populations frequently show elevated serum antibody levels but no symptoms of disease. The same is true of people working in high-risk areas. It has been reported that 62 out of 143 (43.4%) healthy people exposed to a contaminated environment had positive antibody titres against distinct serogroups (Paszko-Kolva et al., 1993).

Virulence factors

Legionellae are intracellular pathogens of macrophages, by which they are phagocytosed in a process involving the complement fragment C3 and the monocyte complement receptors CR1 and CR3. Both virulent and non-virulent strains are phagocytosed, remaining intact inside the phagocytes. Virulent strains can multiply inside the phagocytes and are able to inhibit the fusion of phagosomes with lysosomes; non-virulent strains do not multiply (Horwitz, 1993). Only two products of *Legionella* have so far been shown to be associated with virulence (Fields, 1996)—the 24-kDa protein, macrophage infectivity potentiator, thought to be conserved throughout the genus

(Ciancotto et al., 1989, 1990; Riffard et al., 1996), and the 113-kDa integral protein of the cytoplasmic membrane, which is the product of the *dotA* gene (defect in organelle tracking) (Berger & Isberg, 1993; Berger, Merriam & Isberg, 1994; Roy & Isberg, 1997). Helbig et al. (1995) have proposed that differences in the virulence of *Legionella* species or serogroups are associated with differences of epitopes of the LPS. Within *L. pneumophila* serogroup 1, the strains most commonly associated with disease in humans share a common epitope, as revealed by monoclonal subtyping (Watkins et al., 1985; Ehret, von Specht & Ruckdeschel, 1986; Dournon et al., 1988). Aerosol survival (Dennis & Lee, 1988), growth temperature (Mauchline et al., 1994), the possession of tissue-destructive protease (Baskerville et al., 1986), and the expression of flagellae (Bosshardt, Benson & Fields, 1997) may also be important virulence factors.

The host defence against *Legionella* relies principally on cell-mediated immune mechanisms. One protein produced by *L. pneumophila*, the major secretory protein (MSP, 39kDa), is able to induce protective cell-mediated immunity without being a virulence factor (Blander & Horowitz, 1991). Circulating antibodies are produced during infection with *L. pneumophila* in humans, but they do not seem to be protective and antibody titres rise only slowly; 30% of patients do not produce antibodies detectable by immunofluorescence-coupled antigens up to 4 weeks after infection. Rising levels of serum antibodies, however, are of great diagnostic and epidemiological value. No vaccine has so far been tested in humans.

Dose–response relationship; animal studies

Inoculation of guinea-pigs with material from the lungs of infected individuals resulted in the first isolation of *L. pneumophila* in 1977 (McDade et al., 1977). Since that time, guinea-pigs have been used repeatedly for experimental infection and have proved susceptible to infection by inhalation, although aerosol infection is in fact very difficult to achieve (Yu, personal communication). The lethal dose varies from 2400 to 100000 viable bacteria, but infection can be initiated by as few as 130 organisms. Infections have also been induced in monkeys, rats, and mice, although mice seem to be somewhat resistant, at least in terms of mortality (Baskerville et al., 1981; Collins, 1986). The susceptibility of the A/J mouse strain is due to a single recessive gene conferring permissiveness on A/J macrophages (Beckers et al., 1995). Suckling CD1 mice have been shown to be susceptible to infection and seem to provide a promising animal model for studies of *L. pneumophila* virulence (Castellani Pastoris et al., 1997).

The infective dose for humans can be assumed to be low—possible even a single organism—since *Legionella* infections have frequently been traced to contaminated aerosols generated at distances of up to 3.2km (Addiss et al., 1989). Given the frequency of *L. pneumophila* in human surroundings, the virulence of the organism, and the fact that the infective dose is so low, a much larger number of infections would be expected than is actually the case. It therefore follows that there must be other, as yet unknown, determinants of infection. Infectivity may be substantially enhanced if amoebae are inhaled or aspirated (Brieland et al., 1996). Vacuoles in infected amoebae may contain many hundreds of *Legionella* cells which, when liberated, provide a large inoculum in a restricted area of the respiratory tract (Rowbotham, 1986; O'Brien & Bhopal, 1993; Berk et al., 1998).

Mode of transmission

Inhalation of airborne droplets or droplet nuclei containing legionellae is generally thought to be the commonest mode of transmission. The aerosols may be generated by mechanical devices (e.g. cooling towers of air-conditioning systems) or by the use of potable water, especially from domestic hot-water installations (e.g. showers) (Breiman et al., 1990). In one cluster of infections, *L. longbeachae* was isolated from potting mixes and the soil of potted plants in the vicinity of patients (Steele et al., 1990, 1993, 1996). Three cases of Legionnaires disease due to *L. pneumophila* were reported following the flooding of the basement

of a bar; bacteria were isolated from the sump water (Kool et al., 1998).

Aerosol formation is deemed necessary to cause pneumonic disease, but aspiration following ingestion of contaminated water, ice, and food has also been implicated as the route of infection in some cases (Marrie et al., 1991; Blatt et al., 1993; Venezia et al., 1994; Graman, Quinlan & Rank, 1997). Some authors believe aspiration to be the major mode of transmission (Yu, 1993). Sporadic cases in hospitals have arisen from use of the taps in wash-basins. Even when it is possible to demonstrate that the disease strain and the strain colonizing a plumbing system are identical, the exact route of transmission sometimes remains a matter of speculation. There is no evidence of person-to-person transmission (Fraser, 1977; Yu, 1983).

Outbreaks and single cases of Legionnaires disease have been traced to the cooling towers and evaporative condensers of air-conditioning systems, decorative fountains, ultrasonic nebulizers, room humidifiers, hot whirlpool and spa baths, hot water from taps and showers, and medical devices containing water (e.g. respiratory care devices) (Butler & Breiman, 1998). Of 20 hospital outbreaks of Legionnaires disease in England and Wales between 1980 and 1992, 19 were attributed to *Legionella*-contaminated potable water systems (Joseph et al., 1994). The hot-water plumbing systems of many hospitals are contaminated and colonized by legionellae. The same strain may be identified over extended periods at particular sampling points (Chang et al., 1996), but different strains may colonize different parts of the same building (Marrie et al., 1992).

Disease occurrence: outbreaks, sporadic cases, and prospective studies

Outbreaks

Since the 1976 outbreak in Philadelphia led to the detection and description of the family Legionellaceae, many outbreaks—a number of them spectacular, but most on a smaller scale—have been reported, frequently involving hospitals. Infections have often been traced to colonized parts of air-conditioning plants (Dondero et al., 1980; Addiss et al., 1989; O'Mahoney et al., 1990; Watson et al., 1994), but most outbreaks and recurrent single cases in hospitals are associated with contaminated potable water and hot-water systems (Joseph et al., 1994). Decontamination of colonized installations has been shown to interrupt outbreaks and prevent recurrence of sporadic cases. In two prospective studies in hospitals, the frequency with which *L. pneumophila* was isolated from patients with pneumonia was reduced from 16.3% to 0.1% over a 6-year period and from immunocompromised patients from 76% to 0.8% over a 10-year period (Grosserode et al., 1993; Junge-Mathys & Mathys, 1994). Measures used to achieve this included decontamination of the plumbing systems, monitoring of *Legionella* in the water, examination of all clinical specimens for signs of *Legionella* infection, use of sterilized water for all applications in high-risk patients, and ensuring that all patients and clinical staff were adequately informed of the risks of infection, especially with respect to the use of hot water in high-risk wards.

Travel-associated Legionnaires disease

Legionnaires disease is often associated with travel and with staying in hotels—as was the case in the 1976 outbreak in Philadelphia. A study carried out in Ohio (Straus et al., 1996) on domestic acquisition of Legionnaires disease identified nights spent away from home as a risk factor. In England and Wales, 56% of the 160 cases reported in 1995 occurred in travellers (Newton et al., 1996), and in 1997 the same was true for 114 of the 226 reported cases (Joseph et al., 1998). Among 52 Finnish patients with Legionnaires disease, 76% of those who were not immunosuppressed and had no underlying disease ($n = 17$) had made recent journeys (Skogberg et al., 1994). Small clusters of cases have repeatedly been reported among tourists staying at certain hotels in holiday resorts, especially in the Mediterranean region: 55% of 119 hotels in

various European countries had legionellae in their water distribution systems and 73% had amoebae (Starlinger & Tiefenbrunner, 1996).

Outbreaks reported among passengers on cruise ships have been traced to contaminated water in whirlpool baths (Jernigan, 1996) or to drinking-water (Castellani Pastoris et al., 1999). Gerchikova et al. (1990) have found immunological evidence of increased exposure among railway conductors, subway personnel, and railroad construction workers, and have isolated two strains of *L. pneumophila* from water samples taken from railway dining cars. Water pipes and reservoirs on ships, railway carriages, and the like are often subject to warming and are not easily emptied for cleaning. Chlorine decay and bacterial growth are thus more likely in the water they contain.

The link between travel and Legionnaires disease was discussed at a WHO meeting in 1989 (World Health Organization, 1990). A surveillance scheme for travel-associated Legionnaires disease, instituted by the European Working Group on *Legionella* Infection, coordinated by the Public Health Laboratory Service in London, England, and monitored by WHO, has led to the detection of many cases and improved disease prevention.

Sporadic community-acquired infections

In a prospective study in two counties in Ohio, USA, Marston et al. (1997) showed that most cases of pneumonia caused by *Legionella* are community-acquired and sporadic. The annual incidence (with definite diagnosis) was calculated to be 7.0/100000 adults—approximately 10 times the number of cases reported to health authorities. Community-acquired infections may be caused partly by cooling towers and other aerosol-producing devices, but certain features of domestic plumbing and potable-water supply and water-heating systems have also been shown to be associated with Legionnaires disease and must therefore also be considered as a sources of legionellae (Aldea et al., 1992; Straus et al., 1996).

Plumbing systems in residential premises—particularly one-family houses (Tiefenbrunner et al., 1993)—are less frequently colonized than those in hospitals. However, investigations in different cities in Finland, Germany, and Spain have shown that apartment blocks may be as heavily contaminated as hospitals (Aldea et al., 1992; Lück et al., 1993; Zacheus & Martikainen, 1994). The observed differences may be due to the size of water heaters, the extent of the hot-water installations, and other details of the heating (central versus point-of-use, electric versus gas or oil) and distribution systems (Alary & Joly, 1991).

Monitoring and assessment

Examination of clinical specimens

No specific clinical symptoms of *Legionella* infections distinguish them from pneumonia or localized infections of other origins, and many community-acquired infections will be treated without diagnosis. Definitive diagnosis of a *Legionella* infection relies on the following features:

- increasing serum concentrations of antibodies;
- detection of antigens in the urine;
- detection of bacteria in lung tissue, or in sputum or other secretions, by direct immunofluorescence microscopy;
- culture of *Legionella* from respiratory secretions, bronchoalveolar lavage fluid, pleural fluid;
- detection of *Legionella* nucleic acid by DNA probes or by polymerase chain reaction (PCR).

Up to 4 weeks after infection, 30% of patients do not develop antibodies detectable by indirect immunofluorescence assay (IFA). An acute-phase antibody titre of 1:256 did not discriminate between cases of *Legionella* infection and non-cases, while a positive urine antigen assay was found in 55.9% of cases compared with <1% of non-cases (Plouffe et al., 1995). A fourfold increase in IgG and IgM titres is considered to be a reliable sign of infection, and detection of

Legionella antigen is a fairly sensitive (70%) and highly specific (>99%) method for diagnosis of *L. pneumophila* serogroup 1 infection (Plouffe et al., 1995). Urinary antigen test results will remain positive for several weeks after the onset of infection (Stout & Yu, 1997). However, infections with non-serogroup 1 *L. pneumophila* will be missed unless test kits containing antibodies against other *Legionella* serogroups and species are available. Urinary tests to detect infection with other serogroups and species are being developed.

Detection of bacteria in lung tissue and sputum by direct immunofluorescence as well as by DNA hybridization and PCR is no more successful than the examination of serum for antibodies or of urine for antigen—70% of cases, at best, are detected. Clearly, a positive bacterial culture is the most convincing evidence of infection, but only 9% of 160 cases reported in England and Wales in 1995 were diagnosed by culture (Newton et al., 1996).

To summarize, there is no single laboratory test currently available that will detect all infections caused by *L. pneumophila* or other *Legionella* species (Edelstein, 1993).

Analytical methods for environmental samples

A standard procedure for the isolation, culture, and identification of *Legionella* has been prepared by the International Organization for Standardization (1998). High-yield solid and liquid culture media are commercially available; these are generally optimized for *L. pneumophila*. Recovery rates using these media, and using sample preparation procedures, have yet to be fully evaluated for other *Legionella* species. In dealing with *Legionella* species other than *L. pneumophila*, therefore, the recovery rate should be determined. Steinert et al. (1997) have shown that legionellae may enter a viable but non-culturable state, but become culturable again by cocultivation with axenic *Acanthamoeba castellanii*. Swab specimens from a faucet have been shown to yield 10 times as many legionellae as a 250-ml water sample taken from the same faucet (Ta et al., 1995), reflecting the prevalence of the organisms in biofilms.

Environmental samples frequently need to be concentrated or diluted to give optimal results on solid media. Moreover, background bacteria must be eliminated before, or suppressed during, primary culture. Legionellae and background bacteria can be concentrated by centrifugation (e.g. 6000g for 10 minutes at about 20°C) or by membrane filtration. Numbers of other bacterial species present in the sample can be reduced by heat treatment (50 ± 1°C for 30 ± 2 minutes, or 55°C for 15 minutes) or by acid treatment (3 minutes at pH 2.2). The material is then streaked, or the filter is transferred, onto buffered charcoal–yeast extract (BCYE) agar (Edelstein, 1981), with or without selective supplement. Various improved media for different purposes have been proposed more recently, as has incubation under 2–5% carbon dioxide. A medium containing dyes (bromocresol blue and bromocresol purple), vancomycin, and polymyxin B (DGVP) gave optimal results in a comparative study (Ta et al., 1995).

Plates are incubated at 36 ± 1°C for up to 10 days and examined every 2 or 3 days. Presumptive *Legionella* colonies are examined for their L-cysteine requirement by streaking them onto cysteine-free BCYE agar or other appropriate media, e.g. sheep blood agar, with subsequent incubation. Confirmation of *Legionella*, and species and serotype identification are done using commercially available antisera, preferably by direct immunofluorescence. Commercially available latex agglutination kits may also be used. A more rapid procedure has been proposed to replace examination for L-cysteine requirements, namely a colony blot assay using a genus-specific monoclonal antibody coupled with a chromogenic reagent (Obst, 1996). PCR procedures have also been developed. The DNA-sequence information of the ribosomal 23S–5S spacer region was used to develop a genus- and species-specific detection and identification system for all legionellae, using PCR and reverse dot-blotting (Robinson et al., 1996).

Both environmental strains and clinical isolates can be successfully subtyped by molecular techniques such as ribotyping, macrorestriction analysis by pulsed-field gel electrophoresis, or PCR-based methods (Schoonmaker & Kondracki, 1993; Pruckler et al., 1995; Van Belkum et al., 1996). These yield valuable information on the sources and epidemiology of infections. However,

the results of subtyping alone, in the absence of epidemiological data, cannot reliably implicate a source because the distribution of the various subtypes in the environment is unknown.

Control

Occurrence, transport, and survival in the environment and in source waters

The legionellae have been found in natural freshwater systems, including thermal waters, all over the world and are considered to be part of the natural freshwater microbial ecosystem (Fliermans et al., 1981; Verissimo et al., 1991). The organisms have also been found in sewage-contaminated coastal waters of Puerto Rico (Ortiz-Roque & Hazen, 1987), in well material down to a depth of 1170 metres (Fliermans, 1996), and in low concentrations in groundwater (Frahm & Obst, 1994; Lye et al., 1997). Some outbreaks have been associated with soil and excavation activities. *L. longbeachae*, *L. bozemanii*, and *L. dumoffii* have all been isolated from potting mixes made from composted wood wastes (Hughes & Steele, 1994; Steele & McLennan, 1996).

A characteristic feature of legionellae is their ability to multiply inside protozoa (Rowbotham, 1980). Protozoa that support the growth of legionellae include species of *Acanthamoeba*, *Hartmannella*, *Naegleria*, *Echinamoeba*, *Vahlkampfia*, and *Tetrahymena* (Fields, 1993). Indeed, it has been suggested that environmental growth of legionellae in the absence of protozoa has not been demonstrated, and that protozoa are the natural reservoir for these organisms in the environment (Fields, 1993). However, association with cyanobacteria of the genera *Fischerella*, *Phormidium*, and *Oscillatoria* also promotes relatively rapid growth of *L. pneumophila* (Tison et al., 1980), and cocultivation with some bacteria has been demonstrated in vitro (Wadowsky & Yee, 1985).

Legionellae will not grow in sterilized samples of the water from which they have been isolated. It follows from this that they are part of a microbial ecosystem in which they are both nourished and protected from physical removal by the water current and from antimicrobial agents. They are detected in significant numbers only after other microorganisms have colonized sediments, soil, or biofilms. Growth of other *Legionella*-like organisms in amoebae has been described repeatedly, and—on the basis of 16S rRNA similarity—it has been proposed that these organisms are indeed members of the genus *Legionella* (Rowbotham, 1993; Adeleke et al., 1996).

With the exception of thermal waters and water in tropical regions, legionellae are found in only low concentrations in natural environments (≤ 1 cfu/ml in groundwater); this is to be expected from the low replication rates at temperatures below 25°C. The organisms will be introduced from surface water, soil, and subsoil into water used as the source for preparation of drinking-water and other purposes.

Effects of drinking-water treatment

Storage of raw water in reservoirs will not necessarily reduce numbers of *Legionella*; at elevated temperatures there may even be growth of the organisms. However, as for other bacteria, *Legionella* concentrations can be reduced by coagulation, flocculation, and sedimentation. Growth of *Legionella* may well occur inside filters used for drinking-water preparation (such as granular activated carbon filters) if there is microbial colonization that includes amoebae, but this will be controlled by low temperatures. Significant concentrations will develop only in situations where temperatures rise above 20°C for prolonged periods.

Growth and/or recontamination in distribution systems

At temperatures between 20°C and 50°C, legionellae frequently colonize water distribution systems. The main sites of colonization, bacterial growth, and contamination are the pipework in buildings, boilers (especially if they contain sediment), membrane expansion

vessels and reservoirs inside buildings, as well as the fittings, outlets, and accessory devices connected to water-supply systems. Special mention should be made of medical and dental equipment containing or supplied with water, because it is likely to be used on, or in the vicinity of, susceptible individuals. Colonization is enhanced at temperatures above 25°C, by stagnation, and by formation of biofilms that include protozoa and have an elevated iron content. All these features are common in the warm-water distribution systems of large buildings, including hospitals and other clinical establishments.

Measurable inactivation of legionellae begins at a temperature of 50°C: for *L. pneumophila*, decimal reduction times of 80–111 minutes at 50°C, 27 minutes at 54°C, 19 minutes at 55°C, 6 minutes at 57.5°C, and 2 minutes at 60°C have been recorded (Dennis, Green & Jones, 1984; Schulze-Röbbecke, Rödder & Exner, 1987).

Prolonged stagnation (of several months, for instance during building construction or over holiday periods) resulting in a heavy microbial load has been reported on several occasions when water has been identified as the source of infection (Dondero et al., 1980; Kramer et al., 1992; Breiman, 1993; Mermel et al., 1995; Straus et al., 1996). Pressure-compensation vessels (shock absorbers) also provide the conditions for stagnation (Memish et al., 1992) and should be positioned on the cold-water (i.e. intake) side of hot-water installations.

The concentration of assimilable organic carbon (AOC) in water seems to have less influence on the growth of *Legionella* than on the formation of biofilms. Legionellae are not observed in the absence of other microorganisms. Biofilm formation is encouraged not only by elevated AOC levels but also by certain materials present in a plumbing system. Since legionellae are iron-dependent, it is to be expected that the use of iron piping would encourage their growth; *Legionella*-contaminated water frequently contains high levels of iron as the result of corrosion. However, in a study on the prevalence of legionellae in private homes, the organisms were found only in houses with copper pipework (Tiefenbrunner et al., 1993), and many hospitals in the United Kingdom that have experienced outbreaks of Legionnaires diseases also had copper plumbing. It therefore seems that avoidance of iron or steel pipework does not protect against colonization by *Legionella*.

Materials that promote biofilm formation by nutrients that migrate to surfaces in contact with the water should not be used in water installations, whether as coatings, fillings, or sealants for pipes, reservoirs, or containers, or for devices such as membranes of pressure-compensation vessels, tap washers, etc. (Colbourne et al., 1984; Niedevelde, Pet & Meenhorst, 1986). Biofilms will also form, however, on inert surfaces, albeit more slowly and less extensively, so that the material of which the surface is composed is actually less important than the size of the biofilm-bearing surface. The larger the surface that is available for bacterial growth in a water system, the more likely it is to become colonized by legionellae; thus small water systems in single dwellings are much less likely to become colonized than large systems in, for example, hotels or hospitals.

Control of legionellae in potable-water systems

Prevention

Entry into a potable-water system of single bacteria or bacteria-carrying amoebae from the public supply system, or during construction or repair, must always be considered as a possibility. Prevention of significant bacterial growth is best achieved by keeping water cool (preferably below 15°C) and flowing, or hot (at least 55°C) and flowing. Mains drinking-water supplies can be kept free of significant levels of *Legionella* by chlorination: a concentration of 0.2mg/litre free chlorine will keep levels below 1cfu/100ml, indicating that no active replication is occurring. The low levels of legionellae occasionally found in public water supplies have never been shown to constitute a health risk. Inside buildings, however, the residual chlorine (if any) carried over from the public

supply will not prevent growth of these organisms, and additional measures are required to prevent water stagnating at temperatures that will allow bacterial growth.

The cold water supply should be kept cool, with temperatures at outlets not exceeding 20°C. Pipework, storage tanks, and devices such as water softeners should be insulated against heat gain and should never be situated in rooms where the temperature is constantly high. Hot water must be stored and distributed at a temperature of at least 50°C throughout the system. It is recommended that the water is heated to, and stored at, 60°C, and that it attains 50°C (NHMRC, 1996; Health and Safety Executive, 2000), 55°C (DVGW, 1996), or 60°C (Gezondheidsrad, 1986) at taps after running for no more than 1 minute; temperatures inside boilers and recirculation systems should be similar. For this purpose, the design and construction of the hot-water system must meet certain requirements that are otherwise unnecessary. Water temperatures inside calorifiers and tanks must reach 60°C throughout, including at the bottom, at least once a day. The calorifier must be able to achieve this temperature consistently, even during periods of high demand. For the purpose of thermal disinfection, the calorifier must produce sufficient amounts of water to flush all outlets in the building with water at 70°C. Tanks must be accessible for cleaning and the accumulation of sludge must be avoided. Connected tanks, filters, and other appliances must be scrutinized for their potential to promote *Legionella* growth. Pipework should be as short and easy to survey as possible and should avoid “dead ends” and other zones of stagnation. Outlets should be fitted with mixer taps to reduce the risk of scalding.

Point-of-use water heaters have been proposed as a means of obviating the need for hot-water storage and distribution systems (Muraca, Yu & Goetz, 1990). Even these, however, are not totally failsafe, since growth of legionellae can occur at the outlets (Sellick & Mylotte, 1993).

Since stagnation will give rise to elevated colony counts (and also frequently to high concentrations of legionellae in the water within pipes and reservoirs), it has been proposed that water-supply systems should be drained when there is to be an extended period (e.g. weeks) during which there will be no water consumption.

Particular care should be taken to protect plumbing systems during the construction of new hospital buildings. Before a new or renovated hospital or similar building is opened, the water in the supply system should be tested for microbiological quality, including the presence of *Legionella*.

Eradication/disinfection

When hot-water systems develop problems that cannot be identified or repaired, it is often difficult to keep them permanently free of elevated concentrations of legionellae. Continuous or intermittent treatment for purposes of disinfection or permanent eradication may then be advisable. Techniques for the eradication of *Legionella* include the following:

- thermal disinfection: heating and flushing
- UV irradiation
- use of chlorine, chlorine dioxide, chloramine, ozone, or iodine
- metal ionization (copper and silver).

Raising the water temperature to at least 60°C (Health and Safety Executive, 2000) is the most reliable means of eradicating legionellae from a water-supply system, although the exact temperature and the length of time necessary for heating and flushing the system, including the outlets, remain matters of some debate (Dennis, Green & Jones, 1984; Snyder et al., 1990). An 8log₁₀ reduction in *L. pneumophila* has been demonstrated within 25 minutes at 60°C, 10 minutes at 70°C, and 5 minutes at 80°C. The most resistant species—*L. micdadei*—is about twice as resistant to thermal disinfection as *L. pneumophila* (Stout, Best & Yu, 1986). This is consistent with the finding that *Legionella* in a hospital water system could not be eradicated by raising the temperature in the hot-water tank to 60°C; however, raising the temperature in the tank to 77°C (which produced 50–60°C in the system as a whole) successfully eradicated the organism (Best et al., 1983). At 50–60°C in a model plumbing system, a 7log₁₀ reduction in legionellae occurred in under 3 hours (Muraca, Stout & Yu, 1987).

From the observation of Stout, Best & Yu (1986), it follows that thermal disinfection of plumbing systems requires the water in boilers and tanks to be heated to 70°C and taps (outlets) to be kept open for 30 minutes; see also Plouffe et al. (1983). This measure should succeed in eliminating *Legionella* for some weeks. Reappearance of the organisms in the water is usually accompanied or preceded by elevated concentrations of other bacteria, resulting in an elevated heterotrophic plate count (HPC), i.e. >100 colony-forming units/ml (cfu/ml), which is more easily monitored than the concentration of legionellae. Chlorination of the water, however, may make this indicator useless, because chlorine does not affect legionellae to the same extent as HPC (Zacheus & Martikainen, 1996).

Compared with other Gram-negative bacteria, the legionellae are highly susceptible to UV irradiation (Antopol & Ellner, 1979). In the dark, a 90% reduction has been achieved at 5W·s/m², 99% at 10W·s/m², and 99.9% at 16W·s/m². On exposure to photoreactivating light, however, doses at least 3 times higher are needed because of the organism's effective light-dependent DNA repair system (Knudson, 1985). In hospitals, UV irradiation units installed near "points of use", together with prefiltration systems to prevent accumulation of scale, have been successful in keeping water outlets free of legionellae (Farr et al., 1988; Liu et al., 1995). However, these units are effective only over short distances.

Chlorine is much better tolerated by *Legionella* spp. than by many other bacteria, including *Escherichia coli*. Achieving a given reduction in different species of media-grown *Legionella* required more than 40 times longer than the same reduction in *E. coli* (Kuchta et al., 1983). Tap-water-adapted strains have been reported to be 68 times as resistant as *E. coli* when computed as a product of concentration and time (CT), and experiments using iodine suggest that cultures associated with stainless-steel surfaces are even more resistant (Cargill & Pyle, 1992). The resistance of *Legionella* to chlorine is further enhanced by inclusion of the organisms in amoebae or by growth in biofilms (Kuchta et al., 1993), and it is therefore unsurprising that legionellae have repeatedly been found in chlorinated water that complies with microbiological standards for drinking-water. In reality, the calculation of CT values in laboratory experiments with cultured legionellae is an inadequate indication of resistance to chlorine and other antimicrobial agents.

A chlorine concentration of 2mg/litre will kill free legionellae (Kuchta et al., 1993) and appears to be sufficient to keep the organisms at low levels in hot water (Snyder et al., 1990; Grosserode et al., 1993); even at chlorine levels of 4mg/litre, however, amoebae containing *L. pneumophila* will liberate viable organisms (Kuchta et al., 1993). Continuous hyperchlorination (>2mg/litre) may cause corrosion of pipes and formation of trihalomethanes as by-products (Helms et al., 1988; Grosserode et al., 1993). Nevertheless, supplementary chlorination of the hot-water supply may produce satisfactory results in many situations.

There have been fewer studies of chlorine compounds than of chlorine itself. Chlorine dioxide is probably more effective than chlorine because of its superior oxidative power and effect on biofilms (Walker et al., 1995; Hamilton, Seal & Hay, 1996). Chloramines have a slower action than chlorine but greater stability; Cunliffe (1990) reported that legionellae were much more sensitive than *E. coli* to monochloramine—a compound that is used in Australia to control the growth of *Naegleria fowleri*. In a comparison of hospitals that had reported Legionnaires disease with others that had not, Kool, Carpenter & Fields (1999) revealed that outbreaks were 10 times as likely in a hospital with residual free chlorine in its water than in one where the residual disinfectant was chloramine.

Electrolytically generated copper and silver ions have been shown to be effective in reducing legionellae in vitro (Landeem, Yahya & Gerba, 1989). At 45°C, a 5log₁₀ reduction in legionellae was achieved after 1 hour with silver and copper ion concentrations of 80 and 800µg/litre respectively, and after 24 hours with concentrations of 20 and 200µg/litre (Rohr, Senger & Selenka, 1996). Lin et al. (1996) have also demonstrated a synergistic effect of copper and silver ions. Copper/silver ionization has been used successfully in hot-water recirculating systems, reducing *Legionella* concentrations to 10–100cfu/litre (Colville et al., 1993; Liu et al., 1994; Selenka et al., 1995; Rohr et al., 1996), although there is still no proof of continuing efficiency with prolonged use.

The resistance of legionellae to ozone is comparable to that of *E. coli* and *Pseudomonas aeruginosa* (Domingue et al., 1988): at an ozone concentration of about 0.3mg/litre, a 4–5log₁₀ reduction in the number of organisms was achieved within 20 minutes (Edelstein et al., 1982; Domingue et al., 1988). However, results for the use of ozone to eradicate legionellae from water systems remain ambiguous. It is probably difficult to achieve a sufficient contact time, since adequate levels of residual ozone will not persist in extended domestic water-supply systems. Additional considerations include the safety and corrosive effects of ozone, and compliance with local regulations.

Although each of the disinfection techniques described in this section has proved effective in reducing *Legionella* under controlled conditions, there are differences in their costs and in their suitability for use in large domestic water-distribution systems. In the event of a disease outbreak or other situation requiring immediate action, heat flushing—alone or combined with hyperchlorination—may be the most appropriate measure to apply. To prevent recurrence, the affected system should be checked for any peculiarities of design or operation that predispose to *Legionella* colonization, and these should be corrected, if possible, before any further action is taken.

Conclusions and recommendations

Health risk assessment

The risk of infection following exposure to *Legionella* is difficult to assess and remains a matter of some debate (O'Brien & Bhopal, 1993). Since *Legionella* is ubiquitous in both natural and man-made environments, it must be supposed that most people are frequently exposed, at least to single organisms. Generally, there is either no reaction to such exposure or asymptomatic production of antibodies. Drinking-water from natural sources and from public supplies may carry single organisms or *Legionella*-containing amoebae but, outside hospitals, there are no reports of outbreaks or recurrent cases of disease following consumption or use of drinking-water that has been kept cool and not subjected to prolonged periods of stagnation. However, the inference to be drawn from the many reported outbreaks and documented single cases is that inhalation of small numbers of bacteria, or aspiration following ingestion, will lead to disease.

Risk of infection is acknowledged to be high among transplant patients, patients receiving high-dose steroid treatment or intensive care, individuals being fed by nasogastric tube, and people with malignancies and end-stage renal disease. Special measures of protection and surveillance are essential for people in these categories. Increased susceptibility during outbreaks has also been observed among males, diabetic patients, the elderly, and people with reduced resistance to respiratory disease (e.g. smokers). Nonetheless, no unequivocal dividing line between those at risk and those not at risk has yet been established.

Risk management strategies

Most outbreaks reported to date have been associated with cooling towers, evaporative condensers of air-conditioning devices, potable water at elevated temperatures (especially in hospitals and hotels), hot whirlpool and spa baths, nebulizers, and certain potting composts. The greatest risk seems to be associated with water subjected to prolonged periods of stagnation and in systems that are frequently maintained at temperatures of 25–50°C; this range of temperatures should therefore be avoided as far as possible.

Water systems—particularly cooling towers and evaporative condensers—should be designed, constructed, and operated in such a way that microbial growth is minimized. High water temperature is the most efficient approach to both intermittent disinfection and continuous control. In hot-water distribution systems, water temperatures should exceed 60°C in boilers, reservoirs, and circulating pipes, and reach 50°C at outlets. Continuous surveillance and disinfection have

been proposed for water systems in hospitals and in public swimming pools, hot whirlpool and spa baths and the like, and for medical and dental equipment that uses water. However, opinion continues to be divided on this issue (Centers for Disease Control and Prevention, 1997), and there is no generally accepted threshold limit for the concentration of legionellae in water. Surveillance of the drinking-water and hot-water supply systems in hospitals is recommended by some (Allegheny County Health Department, 1997), and considered prudent in institutions for the elderly and, possibly, in large hotels.

Total prevention of sporadic infections is impossible, because of the widespread occurrence of *Legionella* in all environments. In hospitals, however, all clinical specimens from patients with symptoms of pneumonia should be examined for *Legionella*, *Legionella* antibodies, and *Legionella* antigen. Transplant patients should be scrupulously protected from exposure to *Legionella* during immunosuppression; their drinking-water should be sterilized, and sterilized water should be used for washing these patients.

There are insufficient data to support widespread disinfection of water-supply systems in the absence of any linkage to *Legionella* infections, but in all cases of nosocomial pneumonia every effort must be made to identify the source of infection and implement measures to interrupt transmission. Continuous monitoring of the water, however, is advocated only when antimicrobial measures have to be checked.

References

- Addis DG et al. (1989). Community acquired Legionnaires' disease associated with a cooling tower: evidence for longer distance transport of *Legionella pneumophila*. *American Journal of Epidemiology*, 130:557–568.
- Adeleke A et al. (1996). *Legionella*-like amebal pathogens—phylogenetic status and possible role in respiratory disease. *Emerging Infectious Diseases*, 2: 225–230.
- Antopol SC, Ellner PD (1979). Susceptibility of *Legionella pneumophila* to ultraviolet radiation. *Applied and Environmental Microbiology*, 38:347–348.
- Alary M, Joly JR (1991). Risk factors for contamination of domestic hot water systems by legionellae. *Applied and Environmental Microbiology*, 57:2360–2367.
- Aldea MJ et al. (1992). Outbreak of Legionnaires' disease in a private apartment building. *Enfermedades Infecciosas y Microbiología Clínica*, 10:403–408.
- Allegheny County Health Department (1997). Approaches to prevention and control of *Legionella* infection in Allegheny county health care facilities. Pittsburgh, PA, Allegheny County Health Department.
- Arnow PM, Boyko EJ, Friedman EL (1983). Perirectal abscess caused by *Legionella pneumophila* and mixed anaerobic bacteria. *Annals of Internal Medicine*, 98:184–185.
- Baskerville A et al. (1986). Pulmonary damage caused by a protease from *Legionella pneumophila*. *British Journal of Experimental Pathology*, 67:527–536.
- Baskerville A et al. (1981). Experimental transmission of Legionnaires' disease by exposure to aerosols of *Legionella pneumophila*. *Lancet*, ii:1389–1390.
- Bauling PC, Weil R, Schroter GP (1985). *Legionella* lung abscess after renal transplantation. *Journal of Infection*, 11:51–55.
- Beckers MC et al. (1995). Natural resistance to infection with *Legionella pneumophila*: chromosomal localization of the Lgn1 susceptibility gene. *Mammalian Genome*, 6:540–545.

- Benson RF et al. (1996). *Legionella waltersii* sp. nov. and an unnamed *Legionella* genomospecies isolated from water in Australia. *International Journal of Systematic Bacteriology*, 46:631–634.
- Berger KH, Isberg RR (1993). Two distinct defects in intracellular growth complemented by a single genetic locus in *Legionella pneumophila*. *Molecular Microbiology*, 7:7–19.
- Berger KH, Merriam JJ, Isberg RR (1994). Altered intracellular targeting properties associated with mutations in the *Legionella pneumophila* dotA gene. *Molecular Microbiology*, 14:809–822.
- Berk SG et al. (1998). Production of respirable vesicles containing live *Legionella pneumophila* cells by two *Acanthamoeba* spp. *Applied and Environmental Microbiology*, 64:279–286.
- Best M et al. (1983). Legionellaceae in the hospital water-supply. Epidemiological link with disease and evaluation of a method for control of nosocomial Legionnaires' disease and Pittsburgh pneumonia. *Lancet*, ii: 307–310.
- Blander SJ, Horwitz MA (1991). Vaccination with the major secretory protein of *Legionella* induces humoral and cell-mediated immune responses and protective immunity across different serogroups of *Legionella pneumophila* and different species of *Legionella*. *Journal of Immunology*, 147:285–291.
- Blatt SP et al. (1993). Nosocomial Legionnaires' disease: aspiration as a primary mode of disease acquisition. *American Journal of Medicine*, 95:16–22.
- Boldur I et al. (1987). Isolation of *Legionella pneumophila* from calves and the prevalence of antibodies in cattle, sheep, horses, antelopes, buffaloes and rabbits. *Veterinary Microbiology*, 13:313–320.
- Bosshardt SC, Benson RF, Fields BS (1997). Flagella are a positive predictor for virulence in *Legionella*. *Microbial Pathogenesis*, 23:107–112.
- Breiman RF et al. (1990). An outbreak of Legionnaires' disease associated with shower use: possible role of amoebae. *Journal of the American Medical Association*, 263:2924–2926.
- Breiman RF (1993). Modes of transmission in epidemic and nonepidemic *Legionella* infection: directions for further study. In: Barbaree JM, Breiman RF, Dufour AP, eds. *Legionella: current status and emerging perspectives*. Washington DC, American Society for Microbiology: 30–35.
- Brenner DJ, Feeley JC, Weaver RE (1984). Legionellaceae. In: Krieg NR, Holt JG, eds. *Bergey's manual of systematic bacteriology*, Vol. 1. Baltimore, MD, Lippincott Williams & Wilkins: 279–288.
- Brenner DJ (1986). Classification of Legionellaceae. *Israel Journal of Medical Sciences*, 22:620–632.
- Brieland J et al. (1996). Coinoculation with *Hartmannella vermiformis* enhances replicative *Legionella pneumophila* lung infection in a murine model of Legionnaires' disease. *Infection and Immunity*, 64:2449–2456.
- Butler JC, Breiman RF (1998). Legionellosis. In: Evans AS, Brachman PS, eds. *Bacterial infections of humans*. New York, Kluwer Academic/Plenum: 355–375.
- Cargill KL, Pyle BH (1992). Effects of culture conditions and biofilm formation on the iodine susceptibility of *Legionella pneumophila*. *Canadian Journal of Microbiology*, 38:423–429 (Erratum: *Canadian Journal of Microbiology*, 1992, 38:1089).

- Castellani Pastoris M et al. (1999). Legionnaires' disease on a cruise ship linked to the water supply system: clinical and public health implications. *Clinical Infectious Diseases*, 28:33–38.
- Castellani Pastoris M et al. (1997). Suckling CD1 mice as an animal model for studies of *Legionella pneumophila* virulence. *Journal of Medical Microbiology*, 46:647–655.
- Centers for Disease Control and Prevention (1997). Guidelines for prevention of nosocomial pneumonia. *Morbidity and Mortality Weekly Report*, 46/ RR-1:1–77.
- Chang F et al. (1996). Nosocomial Legionnaires' disease caused by *Legionella pneumophila* serogroup 5: laboratory and epidemiologic implications. *Journal of Infectious Diseases*, 174:1116–1119.
- Cianciotto NP et al. (1989). A *Legionella pneumophila* gene encoding a species-specific surface protein potentiates initiation of intracellular infection. *Infection and Immunity*, 57:1255–1262.
- Cianciotto NP et al. (1990). A mutation in the *mip* gene results in an attenuation of *Legionella pneumophila* virulence. *Journal of Infectious Diseases*, 162:121–126.
- Colbourne JS et al. (1984). Water fittings as sources of *Legionella pneumophila* in a hospital plumbing system. *Lancet*, i:210–213.
- Collins MT (1986). *Legionella* infections in animals. *Israel Journal of Medical Sciences*, 22:662–673.
- Collins MT, Cho SN, Reif JS (1982). Prevalence of antibodies to *Legionella pneumophila* in animal populations. *Journal of Clinical Microbiology*, 15:130–136.
- Colville A et al. (1993). Outbreak of Legionnaires' disease at University Hospital, Nottingham. Epidemiology, microbiology and control. *Epidemiology and Infection*, 110:105–116.
- Cunliffe DA (1990). Inactivation of *Legionella pneumophila* by monochloramine. *Journal of Applied Bacteriology*, 68:453–459.
- Dennis PJ (1993). Potable water systems: insights into control. In: Barbaree JM, Breiman RF, Dufour AP, eds. *Legionella: current status and emerging perspectives*. Washington, DC, American Society for Microbiology: 223–225.
- Dennis PJ, Lee JV (1988). Differences in aerosol survival between pathogenic and nonpathogenic strains of *Legionella pneumophila* serogroup I. *Journal of Applied Bacteriology*, 65:135–141.
- Dennis PJ, Green D, Jones BP (1984). A note on the temperature tolerance of *Legionella*. *Journal of Applied Bacteriology*, 56:349–350.
- Dieterle RR (1927). Methods for the demonstration of *Spirochaeta pallida* in single microscopic sections. *Archives of Neurology and Psychiatry*, 18:73–80.
- Domingue EL et al. (1988). Effects of three oxidizing biocides on *Legionella pneumophila* serogroup 1. *Applied and Environmental Microbiology*, 54:741–747.
- Dondero TJ Jr et al. (1980). An outbreak of Legionnaires' disease associated with a contaminated air-conditioning cooling tower. *New England Journal of Medicine*, 302:365–370.
- Dournon E et al. (1988). Monoclonal antibody reactivity as a virulence marker for *Legionella pneumophila* serogroup 1 strains. *Journal of Infectious Diseases*, 157:496–501.
- Drozanski W (1991). *Sarcobium lyticum* gen. nov., sp. nov., an obligate intracellular parasite of small free-living amoebae. *International Journal of Systematic Bacteriology*, 41:82–87.
- DVGW (1996). *Trinkwassererwärmungs- und Leitungsanlagen; technische Maßnahmen zur Verminderung des Legionellenwachstums. [Drinking-water heating system*

and conduits:technical measures to decrease Legionella growth.] Bonn, Deutscher Verein für das Gas- und Wasserfach (Arbeitsblatt W551).

- Edelstein PH (1981). Improved semiselective medium for isolation of *Legionella pneumophila* from contaminated clinical and environmental specimens. *Journal of Clinical Microbiology*, 14:298–303.
- Edelstein PH (1993). Laboratory diagnosis of Legionnaires' disease: an update from 1984. In: Barbaree JM, Breiman RF, Dufour AP, eds. *Legionella: current status and emerging perspectives*. Washington, DC, American Society for Microbiology: 7–11.
- Edelstein PH et al. (1982). Efficacy of ozone in eradication of *Legionella pneumophila* from hospital plumbing fixtures. *Applied and Environmental Microbiology*, 44:1330–1334.
- Ehret W, von Specht BU, Ruckdeschel D (1986). Discrimination between clinical and environmental strains of *Legionella pneumophila* by a monoclonal antibody. *Israel Journal of Medical Sciences*, 22:715–723.
- Fabbi M et al. (1998). Epidemiological and environmental investigations of *Legionella pneumophila* infection in cattle and case report of fatal pneumonia in a calf. *Journal of Clinical Microbiology*, 36:1942–1947.
- Fallon RJ (1990). *Legionella*. In: Parker MT, Duerden BI, eds. *Topley and Wilson's principles of bacteriology, virology and immunity, Vol. 2*. London: 275–287.
- Fallon RJ et al. (1993). Pontiac fever in children. In: Barbaree JM, Breiman RF, Dufour AP, eds. *Legionella: current status and emerging perspectives*. Washington, DC, American Society for Microbiology: 50–51.
- Farr BM et al. (1988). Evaluation of ultraviolet light for disinfection of hospital water contaminated with *Legionella*. *Lancet*, ii:669–672.
- Fields BS (1993). *Legionella* and protozoa: interaction of a pathogen and its natural host. In: Barbaree JM, Breiman RF, Dufour AP, eds. *Legionella: current status and emerging perspectives*. Washington, DC, American Society for Microbiology: 129–136.
- Fields BS (1996). The molecular ecology of legionellae. *Trends in Microbiology*, 4:286–290.
- Fisher-Hoch SP et al. (1981). Investigation and control of an outbreak of Legionnaires' disease in a district general hospital. *Lancet*, i:932–936.
- Fliermans CB (1996). Ecology of *Legionella*: from data to knowledge with a little wisdom. *Microbial Ecology*, 32:203–228.
- Fliermans CB et al. (1981). Ecological distribution of *Legionella pneumophila*. *Applied and Environmental Microbiology*, 41:9–16.
- Frahm E, Obst U (1994). Investigation of the occurrence of Legionellae in a drinking water distribution system by using improved detection techniques. *Vom Wasser*, 82:127–136.
- Fraser DW et al. (1977). Legionnaires' disease: description of an epidemic of pneumonia. *New England Journal of Medicine*, 297:1189–1197.
- Fry NK, Harrison TG (1998). An evaluation of intergenic rRNA gene sequence length polymorphism analysis for the identification of *Legionella* species. *Journal of Medical Microbiology*, 47:667–678.
- Garrity GM, Brown A, Vickers RM (1980). *Tatlockia* and *Fluoribacter*: two new genera of organisms resembling *Legionella pneumophila*. *International Journal of Systematic Bacteriology*, 30:609–614.

- Gezondheidsraad (1986). Prevention of legionellosis, recommendations from a committee of the Health Council of the Netherlands. The Hague, Gezondheidsraad.
- Gerchikova NM et al. (1990). Study of the immunostucture of some professional groups of the population with respect to *Legionella pneumophila* serogroup 1. *Zhurnal Mikrobiologii, Epidemiologii i Immunobiologii*, 10:95–98 [in Russian].
- Glick TH et al. (1978). Pontiac fever: an epidemic of unknown etiology in a health department. I: Clinical and epidemiologic aspects. *American Journal of Epidemiology*, 107:149–160.
- Goldberg DJ et al. (1989). Lochgoilhead fever: outbreak of non-pneumonic legionellosis due to *Legionella micdadei*. *Lancet*, i:316–318.
- Graman PS, Quinlan GA, Rank JA (1997). Nosocomial legionellosis traced to a contaminated ice machine. *Infection Control and Hospital Epidemiology*, 18:637–640.
- Grosserode M et al. (1993). Continuous hyperchlorination for control of nosocomial *Legionella pneumophila* pneumonia: a ten-year follow-up of efficacy, environmental effects, and costs. In: Barbaree JM, Breiman RF, Dufour AP, eds. *Legionella: current status and emerging perspectives*. Washington, DC, American Society for Microbiology: 226–229.
- Hamilton E, Seal DV, Hay J (1996). Comparison of chlorine and chlorine dioxide disinfection for control of *Legionella* in a hospital potable water supply. *Journal of Hospital Infection*, 32:156–160.
- Health and Safety Executive (2000). *Legionnaires' disease—the control of legionella bacteria in water system: approved code of practice and guidance*. London, HSE Books.
- Health and Safety Executive (1997). *The control of legionellosis including Legionnaires' disease*, 2nd ed. HSE Books.
- Helbig JH et al. (1995). Molecular characterization of a virulence-associated epitope on the lipopolysaccharide of *Legionella pneumophila* serogroup. *Epidemiology and Infection*, 115:71–78.
- Helms CM et al. (1998). Legionnaires' disease associated with a hospital water system. A five-year progress report on continuous hyperchlorination. *Journal of the American Medical Association*, 259:2423–2427.
- Hookey JV et al. (1996). Phylogeny of Legionellaceae on small-subunit ribosomal DNA sequences and proposal of *Legionella lytica* comb. nov. for *Legionella*-like amoebal pathogens. *International Journal of Systematic Bacteriology*, 46:526–531.
- Horwitz MA (1993). Toward an understanding of host and bacterial molecules mediating *Legionella pneumophila* pathogenesis. In: Barbaree JM, Breiman RF, Dufour AF, eds. *Legionella: current status and emerging perspectives*. Washington, DC, American Society for Microbiology: 55–62.
- Hughes MS, Steele TW (1994). Occurrence and distribution of *Legionella* species in composted plant materials. *Applied and Environmental Microbiology*, 60:2003–2005.
- International Organization for Standardization (1998). *Water quality—detection and enumeration of Legionella*. Geneva (ISO 11731).
- Jernigan DB et al. (1996). Outbreak of Legionnaires' disease among cruise ship passengers exposed to a contaminated whirlpool spa. *Lancet*, 347:494–499.
- Johnson JD, Raff MJ, Van-Arsdall JA (1984). Neurological manifestations of Legionnaires' disease. *Medicine*, 63:303–310.

- Joseph CA et al. (1994). Nosocomial Legionnaires' disease in England and Wales, 1980–92. *Epidemiology and Infection*, 112:329–345.
- Joseph CA et al. (1998). Legionnaires' disease in residents of England and Wales: 1997. *Communicable Disease and Public Health*, 1:252–258.
- Junge-Mathys E, Mathys W (1994). Die Legionellose—ein Beispiel für umweltbedingte Infektionen. [Legionellosis—an example of environmentally caused infections.] *Intensiv*, 2:29–33.
- Knudson GB (1985). Photoreactivation of UV-irradiated *Legionella pneumophila* and other *Legionella* species. *Applied and Environmental Microbiology*, 49:975–980.
- Kool JL, Carpenter JC, Fields BS (1999). Effect of monochloramine disinfection of municipal drinking water on risk of nosocomial Legionnaires' disease. *Lancet*, 353:272–276.
- Kool JL et al. (1998). Outbreak of Legionnaires' disease at a bar after a basement flooding. *Lancet*, 351:1030.
- Kramer M et al. (1992). Case study of a *Legionella* epidemic in a rehabilitation clinic. *Zeitblatt für Hygiene und Umweltmedizin*, 193:262–271 [in German].
- Kuchta JM et al. (1983). Susceptibility of *Legionella pneumophila* to chlorine in tap water. *Applied and Environmental Microbiology*, 46:1134–1139.
- Kuchta JM et al. (1993). Effect of chlorine on the survival and growth of *Legionella pneumophila* and *Hartmannella vermiformis*. In: Barbaree JM, Breiman RF, Dufour AF, eds. *Legionella: current status and emerging perspectives*. Washington, DC, American Society for Microbiology: 55–62.
- Landeen LK, Yahya MT, Gerba CP (1989). Efficacy of copper and silver ions and reduced levels of free chlorine in inactivation of *Legionella pneumophila*. *Applied and Environmental Microbiology*, 55:3045–3050.
- Lieberman D et al. (1996). *Legionella* species community-acquired pneumonia. A review of 56 hospitalized adult patients. *Chest*, 109:1243–1249.
- Lin YSE et al. (1996). Individual and combined effects of copper and silver ions on inactivation of *Legionella pneumophila*. *Water Research*, 30:1905–1913.
- Liu Z et al. (1994). Controlled evaluation of copper-silver ionization in eradicating *Legionella pneumophila* from a hospital water distribution system. *Journal of Infectious Diseases*, 169:919–922.
- Liu Z et al. (1995). Efficacy of ultraviolet light in preventing *Legionella* colonization of a hospital water distribution system. *Water Research*, 29: 2275–2280.
- Lowry PW et al. (1991). A cluster of *Legionella* sternal-wound infections due to postoperative topical exposure to contaminated tap water. *New England Journal of Medicine*, 324:109–113.
- Lück PC et al. (1993). Prevalence of *Legionella* species, serogroups and monoclonal subgroups in hot water systems in south-eastern Germany. *Zeitblatt für Hygiene und Umweltmedizin*, 193:450–460.
- Luttichau HR et al. (1998). An outbreak of Pontiac fever among children following use of a whirlpool. *Clinical Infectious Diseases*, 26:1374–1378.
- Lye D et al. (1997). Survey of ground, surface, and potable waters for the presence of *Legionella* species by EnviroAmp[®] PCR *Legionella* kit, culture, and immunofluorescent staining. *Water Research*, 31:287–293.

- Marrie TJ et al. (1991). Control of endemic nosocomial Legionnaires' disease by using sterile potable water for high risk patients. *Epidemiology and Infection*, 107:591–605.
- Marrie TJ et al. (1992). Each water outlet is a unique ecological niche for *Legionella pneumophila*. *Epidemiology and Infection*, 108:261–270.
- Marston BJ, Lipman HB, Breiman RF (1994). Surveillance for Legionnaires' disease: risk factors for morbidity and mortality. *Archives of Internal Medicine*, 154:2417–2422.
- Marston BJ et al. (1997). Incidence of community-acquired pneumonia requiring hospitalization. Results of a population-based active surveillance study in Ohio. *Archives of Internal Medicine*, 157:1709–1718.
- Mauchline WS et al. (1994). Growth temperature reversibly modulates the virulence of *Legionella pneumophila*. *Infection and Immunity*, 62:2995–2997.
- Mayock R, Skale B, Kohler RB (1983). *Legionella pneumophila* pericarditis proved by culture of pericardial fluid. *American Journal of Medicine*, 75:534–536.
- McDade JE et al. (1997). Legionnaires' disease, isolation of a bacterium and demonstration of its role in other respiratory disease. *New England Journal of Medicine*, 297:1197–1203.
- Memish ZA et al. (1992). Plumbing system shock absorbers as a source of *Legionella pneumophila*. *American Journal of Infection Control*, 20:305–309.
- Mermel LA et al. (1995). Association of Legionnaires' disease with construction: contamination of potable water? *Infection Control and Hospital Epidemiology*, 16:76–81.
- Muraca P, Stout JE, Yu VL (1987). Comparative assessment of chlorine, heat, ozone, and UV light for killing *Legionella pneumophila* within a model plumbing system. *Applied and Environmental Microbiology*, 53: 447–453.
- Muraca PW, Yu VL, Goetz A (1990). Disinfection of water distribution systems for *Legionella*: a review of application procedures and methodologies. *Infection Control and Hospital Epidemiology*, 11:79–88.
- Nelson DP, Rensimer ER, Raffin TA (1985). *Legionella pneumophila* pericarditis without pneumonia. *Archives of Internal Medicine*, 145:926.
- Newton LH et al. (1996). Legionnaires' disease surveillance: England and Wales 1995. *Communicable Disease Report Review*, 6:R151–R156.
- NHMRC (1996). *Guidance on control of Legionella*. Canberra, National Health and Medical Research Council.
- Niedeveld CJ, Pet FM, Meenhorst PL (1986). Effect of rubbers and their constituents on proliferation of *Legionella pneumophila* in naturally contaminated hot water. *Lancet*, i:180–184.
- O'Brien S, Bhopal RS (1993). Legionnaires' disease: the infective dose paradox. *Lancet*, 342:5–6.
- Obst U (1996). Colony blot assay for the detection of *Legionella*, results of a comparative study. *Zentralblatt für Hygiene und Umweltmedizin*, 199:91–95.
- O'Mahoney MC et al. (1990). The Stafford outbreak of Legionnaires' disease. *Epidemiology and Infection*, 104:361–380.
- Oredugba O et al. (1980). Acute renal failure in Legionnaires' disease. *Clinical Nephrology*, 13:142–145.
- Ortiz-Roque CM, Hazen TC (1987). Abundance and distribution of Legionellaceae in Puerto Rican waters. *Applied and Environmental Microbiology*, 53:2231–2236.

- Paszko-Kolva C et al. (1993). Prevalence of antibodies against *Legionella* species in healthy and patient populations. In: Barbaree MJ, Breiman RF, Dufour AP, eds. *Legionella: current status and emerging perspectives*. Washington, DC, American Society for Microbiology: 24–26.
- Plouffe JF, Webster LR, Hackman B (1983). Relationship between colonization of hospital buildings with *Legionella pneumophila* and hot water temperatures. *Applied and Environmental Microbiology*, 46:769–770.
- Plouffe JF et al. (1995). Reevaluation of the definition of Legionnaires' disease: use of the urinary antigen assay. Community Based Pneumonia Incidence Study Group. *Clinical Infectious Diseases*, 20:1286–1291.
- Posner MR et al. (1980). Legionnaires' disease associated with rhabdomyolysis and myoglobinuria. *Archives of Internal Medicine*, 140:848–850.
- Pruckler JM et al. (1995). Comparison of *Legionella pneumophila* isolates by arbitrarily primed PCR and pulsed-field gel electrophoresis: analysis from seven epidemic investigations. *Journal of Clinical Microbiology*, 33:2872–2875.
- Riffard S et al. (1998). Species identification of *Legionella* via intergenic 16S–23S ribosomal spacer PCR analysis. *International Journal of Systematic Bacteriology*, 48:723–730.
- Riggs SA et al. (1982). Thrombotic thrombocytopenic purpura complicating Legionnaires' disease. *Archives of Internal Medicine*, 142:2275–2280.
- Robinson PN et al. (1996). Species-specific detection of *Legionella* using polymerase chain reaction and reverse dot-blotting. *FEMS Microbiology Letters*, 140:111–119.
- Rohr U, Senger M, Selenka F (1996). Effect of silver and copper ions on the survival of *Legionella pneumophila* in tap water. *Zeitschrift für Hygiene und Umweltmedizin*, 198:514–521.
- Rowbotham TJ (1980). Preliminary report on the pathogenicity of *Legionella pneumophila* for freshwater and soil amoebae. *Journal of Clinical Pathology*, 33:1179–1183.
- Rowbotham TJ (1986). Current views on the relationships between amoebae, legionellae and man. *Israel Journal of Medical Sciences*, 22:678–689.
- Rowbotham TJ (1993). Legionella-like amoebal pathogens. In: Barbaree JM, Breiman RF, Dufour AP, eds. *Legionella: current status and emerging perspectives*. Washington, DC, American Society for Microbiology: 137–140.
- Roy CR, Isberg PR (1997). Topology of *Legionella pneumophila* dotA: an inner membrane protein required for replication in macrophages. *Infection and Immunity*, 65:571–578.
- Schoonmaker DJ, Kondracki SF (1993). Investigation of nosocomial Legionellosis using restriction enzyme analysis by pulsed-field gel electrophoresis. In: Barbaree JM, Breiman RF, Dufour AP, eds. *Legionella: current status and emerging perspectives*. Washington, DC, American Society for Microbiology: 189–194.
- Schulze-Röbbecke R, Rödder M, Exner M (1987). Multiplication and killing temperatures of naturally occurring Legionellae. *Zentralblatt für Bakteriologie, Mikrobiologie und Hygiene*, 184:495–500.
- Selenka F, Rohr U, Völker M (1995). Studies on reducing the *Legionella* load of a hospital warm-water system by using the Tarn-Pure procedure. *Hygiene und Medizin*, 20:292–302.
- Sellick JA Jr, Mylotte JM (1993). Nosocomial *Legionella pneumophila* pneumonia in a hospital with an instantaneous hot water heater. In: Barbaree JM, Breiman RF, Dufour AD, eds. *Legionella:*

- current status and emerging perspectives*. Washington, DC, American Society for Microbiology: 43–45.
- Shelton BG, Morris GK, Gorman GW (1993). Reducing risks associated with *Legionella* bacteria in building water systems. In: Barbaree JM, Breiman RF, Dufour AP, eds. *Legionella: current status and emerging perspectives*. Washington, DC, American Society for Microbiology: 279–281.
- Skogberg K et al. (1994). Effect of immunosuppressive therapy on the clinical presentation of legionellosis. *European Journal of Clinical Microbiology and Infectious Diseases*, 13:535–541.
- Snyder MB et al. (1990). Reduction in *Legionella pneumophila* through heat flushing followed by continuous supplemental chlorination of hospital hot water. *Journal of Infectious Diseases*, 162:127–132.
- Starlinger R, Tiefenbrunner F (1996). Legionellae and Amoebae in European hotel water distribution systems. In: *Proceedings of the 11th Meeting of the European Working Group on Legionella Infections*. Oslo, Norwegian Defence Microbiological Laboratory: 67–70.
- States SJ et al. (1993). Temperature and the survival and multiplication of *Legionella pneumophila* associated with *Hartmannella vermiformis*. In: Barbaree JM, Breiman RF, Dufour AP, eds. *Legionella: current status and emerging perspectives*. Washington, DC, American Society for Microbiology: 147–149.
- Steele TW (1993). Interactions between soil amoebae and soil legionellae. In: Barbaree JM, Breiman RF, Dufour AF, eds. *Legionella: current status and emerging perspectives*. Washington, DC, American Society for Microbiology: 140–142.
- Steele TW, McLennan AM (1996). Infection of *Tetrahymena pyriformis* by *Legionella longbeachae* and other *Legionella* species found in potting mixes. *Applied and Environmental Microbiology*, 62:1081–1083.
- Steele TW, Lanser J, Sangster N (1990). Isolation of *Legionella longbeachae* serogroup 1 from potting mixes. *Applied and Environmental Microbiology*, 56:49–53.
- Steinert M et al. (1997). Resuscitation of viable but nonculturable *Legionella pneumophila* Philadelphia JR32 by *Acanthamoeba castellanii*. *Applied and Environmental Microbiology*, 63:2047–2053.
- Stout JE, Yu VL (1997). Legionellosis. *New England Journal of Medicine*, 337:682–687.
- Stout JE, Best MG, Yu VL (1986). Susceptibility of members of the family Legionellaceae to thermal stress: implications for heat eradication methods in water distribution systems. *Applied and Environmental Microbiology*, 52:396–399.
- Straus WL et al. (1996). Risk factors for domestic acquisition of Legionnaires disease. *Archives of Internal Medicine*, 156:1685–1692.
- Ta AC et al. (1995). Comparison of culture methods for monitoring *Legionella* species in hospital potable water systems and recommendations for standardisation of such methods. *Journal of Clinical Microbiology*, 33:2118–2123.
- Tang P, Krishnan C (1993). Legionellosis in Ontario, Canada: Laboratory aspects. In: Barbaree JM, Breiman RF, Dufour AP, eds. *Legionella: current status and emerging perspectives*. Washington, DC, American Society for Microbiology: 16–17.
- Tiefenbrunner E et al. (1993). Occurrence and distribution of *Legionella pneumophila* in water systems of central European private homes. In: Barbaree JM, Breiman RF, Dufour AP, eds. *Legionella: current status and emerging perspectives*. Washington, DC, American Society for Microbiology: 235–238.

- Tison DL et al. (1980). Growth of *Legionella pneumophila* in association with blue-green algae (*Cyanobacteria*). *Applied and Environmental Microbiology*, 39:456–459.
- Van Belkum A et al. (1996). Serotyping, ribotyping, PCR-mediated ribosomal 16S–23S spacer analysis and arbitrarily primed PCR for epidemiological studies on *Legionella pneumophila*. *Research in Microbiology*, 147:405–413.
- Venezia RA et al. (1994). Nosocomial legionellosis associated with aspiration of nasogastric feedings diluted in tap water. *Infection Control and Hospital Epidemiology*, 15:529–533.
- Verissimo A et al. (1991). Distribution of *Legionella* spp. in hydrothermal areas in continental Portugal and the island of Sao Miguel, Azores. *Applied and Environmental Microbiology*, 57:2921–2927.
- Wadowsky RM, Yee RB (1985). Effect of non-Legionellaceae bacteria on the multiplication of *Legionella pneumophila* in potable water. *Applied and Environmental Microbiology*, 49:1206–1210.
- Walker JT et al. (1995). Control of *Legionella pneumophila* in a hospital water system by chlorine dioxide. *Journal of Industrial Microbiology*, 15:384–390.
- Watkins ID et al. (1985). *Legionella pneumophila* serogroup 1 subgrouping by monoclonal antibodies—an epidemiological tool. *Journal of Hygiene*, 95:211–216.
- Watson JM et al. (1994). Piccadilly Circus legionnaires' disease outbreak. *Journal of Public Health Medicine*, 16:341–347.
- World Health Organization (1990). Epidemiology, prevention and control of legionellosis: memorandum from a WHO meeting. *Bulletin of the World Health Organization*, 68:155–164.
- Yu VL (1993). Could aspiration be the major mode of transmission for *Legionella*? *American Journal of Medicine*, 95:13–15.
- Yu VL et al. (1983). Lack of evidence for person-to-person transmission of Legionnaires' disease. *Journal of Infectious Diseases*, 147:362.
- Zacheus OM, Martikainen PJ (1994). Occurrence of legionellae in hot water distribution systems of Finnish apartment buildings. *Canadian Journal of Microbiology*, 40:993–999.
- Zacheus OM, Martikainen PJ (1996). Effect of heat flushing on the concentrations of *Legionella pneumophila* and other heterotrophic microbes in hot water systems of apartment buildings. *Canadian Journal of Microbiology*, 42:811–818.

¹ This review was prepared by K. Botzenhart, Hygiene-Institut des Universität, Tübingen, Germany, with contributions from J. Bartram, Water, Sanitation and Health, World Health Organization, Geneva, Switzerland; J. Butler, Centers for Disease Control and Prevention, Atlanta, GA, USA; A.H. Havelaar, Microbiological Laboratory of Health Protection, Rijksinstituut voor Milieuhygiene en Volksgezondheid, Bilthoven, Netherlands; J. Lee, Public Health Laboratory, Nottingham, England; T. Mariee, Queen Elizabeth II Health Science Centre, Halifax, Nova Scotia, Canada; C. Pastoris, Istituto Superiore di Sanità, Rome, Italy; J. Plouffe, University Hospitals, Columbus, OH, USA; F. Tiefenbrunner, Technological Hygiene, Innsbruck, Austria; V. Yu, Pittsburgh University, Pittsburgh, PA, USA.

Table 5. *Legionella* species and serogroups and their association with disease

Legionella species	Serogroups	Pathogenicity for humans
---------------------------	-------------------	---------------------------------

<i>L. adalaidensis</i>		
<i>L. anisa</i>		+
<i>L. birminghamensis</i>		+
<i>L. bozemanii</i>	2	+
<i>L. brunensis</i>		
<i>L. cherrii</i>		
<i>L. cincinnatiensis</i>		+
<i>L. donaldsonii</i> ^a		
<i>L. dumoffii</i>		+
<i>L. erythra</i>	2	
<i>L. fairfieldensis</i>		
<i>L. feeleii</i>	2	+
<i>L. gesstiana</i>		
<i>L. gormanii</i>		+
<i>L. gratiana</i>		
<i>L. hackeliae</i>	2	+
<i>L. israelensis</i>		+
<i>L. jamestowniensis</i>		
<i>L. jordanis</i>		+
<i>L. lansingensis</i>		
<i>L. londiniensis</i>	2	
<i>L. longbeachae</i>	2	+
<i>L. lytica</i> ^b		
<i>L. maceachernii</i>		+
<i>L. micdadei</i>		+
<i>L. moravica</i>		
<i>L. nautarum</i>		
<i>L. oakridgensis</i>		+
<i>L. parisiensis</i>		+
<i>L. pneumophila</i>	15	+
<i>L. quateirensis</i>		
<i>L. quinlivanii</i>	2	
<i>L. rubrilucens</i>		
<i>L. sainthelensi</i>	2	+
<i>L. santicrucis</i>		+
<i>L. shakespearei</i>		
<i>L. spiritensis</i>		
<i>L. steigerwaltii</i>		
<i>L. tucsonensis</i>		+
<i>L. wadsworthii</i>		+
<i>L. waltersii</i> ^c		
<i>L. worsleiensis</i>		

^a Adeleke et al., 1996.

^b Drozanski, 1991.

^c Hookey et al., 1996.